



● POWER WIRING INTERFACE POINTS
 ○ CONTROL WIRING INTERFACE POINTS
 * ALL CONTROL WIRING IS DISCRETIONARY

REMOTE ALARM CONTACT*
 0.6A @ 125VAC
 0.6A @ 110VAC
 2.0A @ 30VDC



Utility Systems Technologies, Inc.
 PO Box 110, Latham New York 12110

TITLE:
 STD 3 PH AUTOTRANSFORMER SURE-VOLT ELECTRICAL SCHEMATIC

REV: 2 DATE: January 22, 2009
 REV: 1 DATE: AUGUST 15, 2008
 REV: 0 DATE: DECEMBER 03, 2007

SIZE:	DWG NO.:	REV:
A	EVR-0000-000Y-000	1

PROPRIETARY AND CONFIDENTIAL - THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF UTILITY SYSTEMS TECHNOLOGIES, INC.
 ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF UTILITY SYSTEMS TECHNOLOGIES, INC. IS PROHIBITED

SCALE:	SHEET:
NONE	1 OF 1